

ETSA Utilities' Requirements

- 1) Completion of the upgrade of the existing Mount Barker Substation and new bulk supply substation at Mt Barker South in 2011.
- 2) Mount Barker East Substation (future)
A new substation site and substation (Mount Barker East) will be required.
- 3) Nairne West Substation (future)
A new substation site and substation (Nairne West) will be required.
- 4) 66kV overhead line extension will be required from the existing Mount Barker Substation south then east of the existing Mount Barker Township.
- (5) Provision of the required 66kV overhead line easements (26m) between the substations and to the proposed Mt Barker South bulk supply substation.

ETSA Utilities Mount Barker Area Structural Plan

Revision D
April 2011



- Substation
- Future Substation
- Existing 66kV Line
- Future 66kV line
- Existing 33kV Line
- ENET 275kV Transmission Line
- ENET 132kV Transmission Line
- Future Growth Area
- Planned Development
- Development Zones

0.0 0.5 1.0 1.5
Kilometres

The proposed substation location and line configuration are not fixed or finalized and are only to show high level planning of the area.



